

KEPCO's HVDC Utilization and Operation Plan for Net zero

2023. 6. 14

KEPCO RI (Research Institute)

Senior researcher(Ph.D) HyunKeun Ku

CONTENTS

- I Overview of the Korea Power Grid**
- II CFI* Strategy for Renewable energy
penetration in Jeju island**
- III Korea HVDC projects**
- IV Research Projects**
- V Discussion**

* : Control, Flexibility and Inertia


CONTENTS

I Overview of the Korea Power Grid

*** : Control, Flexibility and Inertia**

Active Grid Project team

Overview of the Korea Power Grid



- KEPCO is the sole Transmission Owner (TO) in South Korea (※ KPX is System Operator(SO))
- KEPCO : Planning, Constructing and O&M
(T/L, S/S, HVDC, FACTS, and ESSs)
- KPX : Operation and market.
- KEPRI is the research institute of KEPCO
 - KEPCO : 24,000 workers
 - KEPRI : 700 researchers

Our Team Research Areas

- Future grid planning, HVDC, FACTS analysis, and its application
- Renewable energy hosting capacity and impact study
- Real Time Simulator(RTDS), HILS for Replica Controller, and other devices

NDC and Trends in Power Policies for Carbon Neutrality Overview

- Continued **Expansion of Renewable Energy Expected** in line with NDC Upward Revision
- (9th Basic Plan) for Electricity (hosting) Requires 50.6GW of Renewable Energy Integration
 - Commercial operation status : 27.1GW, '22.6


Renewable Energy Share and Capacity by Energy Policy

Policy	target	Re-E gen ratio	Re-E capa.	—
8 th basic Plan power supply	'30	20%	58.6GW	PV (34GW), Wind(18GW)
9 th basic Plan power supply	'34	26.1%	77.8GW	PV(46GW), Wind(24GW)
3 rd basic Plan energy	'40	30 ~ 35%	114 ~ 140GW	-
NDC object	'30	20 ~ 30%	61.3 ~ 97.8GW	Nuclear gen 30%↑
2050 Net Zero	'50	61%	613.9GW	net zero plan B

- Systematic Expansion of Renewable Energy
- Establishment of Timely Stable Power Grid Needed

2030, 2050 Gen mix ratio Prospects (Estimated)

Overview



Current Status of Domestic Re-E (9th basic Plan)

Overview


Commercial Operation Status : 27.1GW

Re-E	PV	Wind	Etc	Total
Capacity (GW)	21.2(79%)	2.0(7%)	3.9(14%)	27.1(100%)

Connection application Status : 30.7GW (excluding commercial)


Re-E	PV	Wind	Etc	Total
Capacity (GW)	+11.6(38%)	+14.9(47%)	+4.7(15%)	+30.7(100%)

Total commercial




PV Wind ETC

Total application



PV Wind ETC

Sum




PV Wind ETC

※ ETC : Fuel cell, Hydro, Biomass, Organic...


Forecast for the Proportion of Renewable Energy Generation Overview

→ : 10%('22) → 20%('30) → 26%('34)

Forecast for the proportion of Re-E ('22~ '34, IEA phase)



8 Laboratory / 2 Office / 2 Center, 664 People



✓ Human Resource : 664 people [Researcher : 469, Others : 195]

KEPCO Research Institute [Daejeon]	Electric Power Test Center [Gochang]	Fundamental Research Center [Seoul]	New Energy Technology Lab. [Naju]
			

Performing a pivotal role in the Electric power industry R&D



Securing Future Growth Engines

- Leading Carbon Neutrality (Energy Transition) and Digital Transformation
- Development of eco-friendly technology

Development of Power supply stabilization Tech.

- Improving the performance of power facilities
- Operation and prevention/diagnosis Tech.


Contribution to Management

- Gain revenue, cost-saving technology
- Tech-commercialization and resolving issues

Leading Electric power industry R&D

- Technical cooperation between institutions
- Joint research and Technical support

'22 R&D Investment Plan : 550 Project, EUR 1.76 billion



CONTENTS

II CFI* Strategy for Renewable energy penetration in Jeju island

* : Control, Flexibility and Inertia

Status and Prospects of RE in Jeju

- (S&D) **Over generation owing to RE penetration increase**(1% load of mainland's)

- RE capacity 871MW(40%) / Jeju Gen cap 2,181MW('21)


Contents	Max demand	Sources				Remarks
		SG	RE	HVDC	total	
Cap(MW)	1,012('21)	910 (42%)	871 (40%)	400 (18%)	2,181 (100%)	over cap than needed(1169MW)

- (RE Pros.) 13% grow by year, **Gen cap with 3 times the demand in 2034**

- Jeju Gen cap(5.7GW*), Demand(1.4GW), RE cap 78.6% of Jeju Gen cap

- * Jenu Gen cap('34) : SG 0.6GW, HVDC 0.6GW, **RE 4.5GW**

- RE share in Jeju(estimated) : 15%('21) → 34%('25) → 71%('30)



cf. RE penetration level in main land

- 10%('21) → 16%('25) → 20%('30)

Issues of RE penetration increase in Jeju

- (Flexibility) 10 min. reserve not enough to compensate RE variation


Contents	2018	2019	2020	2021
RE Capacity [MW]	452	580	774	812
Curtailed Energy[MWh]	1,366	9,223	19,449	10,158



2030
3,982
724,272




- **Lack of Flexibility since 2025** → flexible resource needed

* flexibility increase by SG, ESS, dispatchable RE, RE forecast/monitoring/control, HVDC



Our Goal for RE in Jeju Grid

Demonstration of CFI (Control, Flexibility, Inertia) in Jeju to improve the system stability and RE penetration level

	RE output control (Control) Real-time curtail	Grid flexibility (Flexibility) ESS for NTAs	System inertia (Inertia) Flywheel Sync Condenser GFM for artificial inertia
Tech			
Def	RE output control remotely using RE forecasting and monitoring system	ESS to relieve transmission congestion which may occur according to RE variability	System inertia improvement using flywheel SC and Inverter-based Resources
items	<ul style="list-style-type: none">- Forecast and monitor RE- Estimate penetration level- Remote control of RE output (real-time, day-ahead)- Grid code of RE	<ul style="list-style-type: none">- NTA ESS control for congestion relief (Non-Transmission Alternatives)- Multi-purpose ESS- Grid Planning considering NTAs	<ul style="list-style-type: none">- Demonstration of Flywheel Synchronous Condenser- Design of Flywheel SC- IBR and artificial inertia for RE and ESS

CONTENTS

III Korea HVDC projects


HVDC Projects

Large scale renewable E connection & concentration of power generation
→ Expand transmission lines

Demand high-capacity power transmission and increased stability
→ Increase IBR(HVDC, FACTS, ...) facilities

AC-DC complex power grid
→ Advanced operational strategy (control interaction, interoperability)

★ power system analysis
→ System impact analysis, operating system, DC based facilities performance verification



CONTENTS

IV Research Projects

Overview (Our team)

Research Projects (recent 3y)


- **Developing** stable **operation strategy and control performance optimization** technology according to the completion of GW-level **Embedded HVDC** and changes in system operation conditions ('20.01 ~ 22.12 / 1.2£M)
- Optimal **asynchronous power grid division** technology development and operating system design **using VSC HVDC** ('21.01 ~ 22.12 / 0.5£M)
- Analysis of **renewable energy hosting capacity** and development of **automated stability analysis tool** for long-term transmission grid ('23.02 ~ 25.07 / 0.9£M)
- Development and demonstration of **online supervisory HVDC control system** ('23.03 ~ 27.02 / 3.9£M)
- Development and demonstration of **online power generation constraint assessment system** based on dynamic stability ('23.07 ~ 26.06 / 2.3£M)

Our laboratory configuration


Research Projects




[Real Time Digital Simulator]



[HVDC/FACTS replica controller]



[Replica controller operating]



[KEPCO SCADA Client]

Replica Controller Status

- In operation
 - 2 TCSC Controllers ('19, ABB) ,1 STATCOM ('20, LS Electric)
- To be Installed
 - 1 Bi-pole LCC HVDC Controllers ('22, GE)
 - 1 VSC BTB HVDC Controllers ('24, Hyosung)
 - 1 VSC BTB HVDC Controllers ('24, GE)

Study Cases

- FACTS Dynamic Performance Test ('18~)
- Field fault reproduction and analysis
 - Shinjecheon TCSC gain tuning ('19~21)
 - HVDC/STATCOM interaction test ('21)
 - SSTI analysis ('22~)
 - Domestic BTB HVDC DPT ('23.6~)

Major Performance


Research Projects

HVDC/FACTS Dynamic Performance Test (DPT)


Grid voltage, current, frequency, CB status, control signals, etc



RTDS



Ex) voltage fluctuation upon fault



Ex) STATCOM reactive power



Verification target controller

Output, control signals

Concept of DPT connection with RTDS and target controller

Deliverable – In house Tool #1

Research Projects

HVDC ELCAT(Entire Life-cycle Analysis Tool)



- **Purpose** : Automatically analysis in total HVDC optimal power transfer range
- Pre-installation required : PSS/E(over v33.4)
- Data managing : System topology(*.sav, *.raw), Contingency list(*.con), Monitoring(*.sbsxml), Harmonic impedance(*.csv), UIF gen list(*.csv)
- Analysis Modules : SCR, FFTOV, UIF, MIIF, GSE, RPC Harmonic Impedance scanning, Filter performance/rating, Reliability(overload, over/under voltage)

Planning (Specification)

- Select HVDC rating
- Main control scheme
- System strength(SCR)
- Reactive Power Capability
- Harmonic impedance Scan
- Screening interaction

Design Verification

- Temporary Overvoltage
- Filter design
- Main scheme parameter
- Damping control (POD, SSDC, etc)

Operation

- System stability
- Facility rating
- Harmonic performance
- Interaction study
- Remedial/mitigation action

Deliverable – In house Tool #1

Research Projects

HVDC ELCAT HMI Overview

Each module analysis results

Data managing

Analysis module selection

Analysis option

Setting Files List


1.Network : C:/main_v21.2/HVDC_Script/ROOT/1.Network/1.2021winOffPeak.sav
2.Dynamic Main : C:/main_v21.2/HVDC_Script/ROOT/2.Dynamic/1.2021winOffPeak.dyr
UDM : C:/main_v21.2/HVDC_Script/ROOT/2.Dynamic/dll/UDM_HVDC_복합전고역.dll
3.Contingency Main : C:/main_v21.2/HVDC_Script/ROOT/3.Contingency/Contingency_Main2.con

Windows 정품 인증
[설치]으로 이동하여 Windows를 정품 인증합니다.

Deliverable – In house Tool #1

Research Projects

Operation Range Analysis Result



HVDC전송가능 영역 평가 툴 HMI화면



상정고장별 HVDC전송가능 영역 분석 결과

Deliverable – In house Tool #2

Research Projects

RTDS Pre/Post Processing Tool

- **Purpose** : Reducing errors and associations when converting RTDS DB by processing PSS/E DB
- **Pre-installation required** : PSS/E
- **History** : Developed **ver1** in 2019(Network, Dynamic, RTDS, Miscellaneous)
Developed **ver2** in 2022(DB consistency comparison, Add Dyr default parameters, etc.)

Network

- Data Error Correction
(Parameter Range, etc)
- **Steady State Check**
(Topology, Slack, etc)
- Renew Energy Aggregation
- Resource Minimization
- Conversion & Integrity
- **Result Verification**

Dynamic

- modify Gen X Source
- Control System Limit
- Impedance Correction
- Numerical Stability Correct
- Governor Limit Constraint
- **Gen Model Parameter**

RTDS

- Short Line Compensation
- Rack and Process Allocation

Miscellaneous

- Conversion Validation
- **Generator Dynamic Response**
- Modeling
- RTDS case Analysis
- **RTDS Rack Manual Allocation**
- **SSTI Analysis**

Deliverable – In house Tool #2 Research Projects

RTDS Pre/Post Processing Tool



RTDS Pre/Post Processing Program

Netw Network Dynamic RTDS Miscellaneous Setting

Result Verification

PSS/E Network Data (*.sav, *.raw)

First Data: 22-23win_peak_93200MW(max).sav

Second Data: 22-23win_peak_93200MW(max)_P3.raw

Inputs : PSS/E data (sav / raw)

Inputs : PSS/E data (_P3.raw)

Interested Subsystem (*.sbsxml)

Optional Data

	Bus number	Bus name	Area name	voltage(pu)[Before]	voltage(pu)[after]	Voltage
1	8	압연변전	대구	1.0546		154.
2	9	동해변전	대구	1.0548		154.
3	17	포철소내	대구	1.0452		154.
4	18	포철소내	대구	1.0439	1.0436	154.
5	19	개폐소	대구	1.052	1.0517	154.
6	28	포스코5	대구	1.0263		11.0
7	29	포스코6	대구	1.0263		11.0
8	30	포스코7	대구	1.0263		11.0
9	31	포스코8	대구	1.0263		11.0
10	32	해안변전	대구	1.0548		154.
11	42	수전변전	대구	1.0544		154.

Bus Machine Branch

Save Run Close

Output : Compare data (csv)

Message Log Progress

Deliverable – In house Tool #2 Research Projects

RTDS Pre/Post Processing Tool



	A	B	C	D	E	F	G	H	I
1	Bus number	Bus name	Area name	Area ID	Pmin(MW)	Pmax(MW)	Qmin(Mvar)	Qmax(Mvar)	Mbase
2	0	8 압연변전	대구	1	1.0550095			154	
3	1	9 동해변전	대구	1	1.0551846			154	
4	2	17 포철소내	대구	1	1.0455332			154	
5	3	18 포철소내	대구	1	1.0442708	1.0438194		154	-0.000451 0.0432193
6	4	19 개폐소	대구	1	1.0523599	1.051905		154	-0.000455 0.0432269
7	5	28 포스코5	대구	1	1.0266926			11	
8	6	29 포스코6	대구	1	1.0266926			11	
9	7	30 포스코7	대구	1	1.0266926			11	
10	8	31 포스코8	대구	1	1.0266926			11	
11	9	32 해안변전	대구	1	1.0551847			154	
12	10	42 수전변전	대구	1	1.0547475			154	

PPRO
Program

From Voltage Gap

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	
1	Bus number		Bus name	Area name	ID	Pmin(MW)	Pmax(MW)	Qmin(Mvar)	Qmax(Mvar)	Mbase	h(MW)	h(Mvar)	h(Mvar)	Pdev(MW)	Pdev(Mvar)	Perr(%)	Qerr(%)	Prate(%)	Qrate(%)
2	0	21421	파주열GT1	경기북부	1	115	162	-70	98	220	153.89999	32.44458	1.4210052	0.6064873	0.9233303	1.8693023	0.6459115	0.275076	
3	1	21422	파주열GT2	경기북부	1	115	162	-70	98	220	153.89999	32.44458	1.4210052	0.6064873	0.9233303	1.8693023	0.6459115	0.275076	
4	2	21423	파주열ST1	경기북부	1	59.700001	172	-70	98	227	163.39999	44.14027	1.5149994	0.57687	0.9271722	1.3069018	0.6674006	0.2541277	
5	3	21441	포천GT1	경기북부	1	173	238.00002	-110	155	355	234.8	67.876091	2.2229919	0.9971237	0.9467598	1.4690353	0.6261949	0.2808799	
6	4	21442	포천GT2	경기북부	1	173	238.00002	-110	155	355	234.8	10.716651	2.2229919	1.219223	0.9467598	11.376903	0.6261949	0.3434431	
7	5	21443	포천ST1	경기북부	1	87	245	-100	137	315.79999	242.40001	13.079314	2.2979889	1.2828865	0.9480152	9.8085151	0.7276723	0.4062339	
8	6	21444	포천GT3	경기북부	1	173	236.5	-110	155	355	233.2	10.775355	2.2070007	1.1865625	0.9463983	11.011818	0.6216903	0.334243	
9	7	21445	포천GT4	경기북부	1	173	236.5	-110	155	355	233.2	67.879974	2.2070007	0.9958191	0.9463983	1.4670293	0.6216903	0.2805124	
10	8	21446	포천ST2	경기북부	1	87	244	-100	137	315.79999	240.00002	13.153669	2.2739868	1.2495651	0.9474944	9.4997456	0.7200719	0.3956824	
11	9	21471	포천천연G	경기북부	1	232	290	-129	180	413	275.5	26.445702	2.6260071	1.2101345	0.9531786	4.5759214	0.6358371	0.2930108	
12	10	21472	포천천연G	경기북부	1	232	290	-129	180	413	275.5	26.139174	2.6260071	1.2112827	0.9531786	4.6339749	0.6358371	0.2932888	

Generator P & Q Gap

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
1	From Bus num	Bus num	Branch name	Area name	Area name	ID	Rate A(MV)	Rate B(MV)	Rate C(MV)	Rate D(MV)	Rate E(MV)	Rate F(MV)	Rate G(MV)	Rate H(MV)	Rate I(MV)	Rate J(MV)	Rate K(MV)	Rate L(MV)
2	0	8	9 압연변전--	대구	대구	1	3.0822439	0.0001154	-9.043303									
3	1	8	9 압연변전--	대구	대구	2	3.0822439	0.0001154	-9.043303									
4	2	8	42 압연변전--	대구	대구	1	7.399601	-0.000173	21.710428									
5	3	8	42 압연변전--	대구	대구	2	4.8277578	-0.000173	21.710428									
6	4	8	130 압연변전--	대구	대구	1	2.8369823	5.7669E-5	-12.66713									
7	5	8	130 압연변전--	대구	대구	2	8.6347141	5.7669E-5	-12.66713									
8	6	9	32 동해변전--	대구	대구	1	0.0820218	-4.562E-6	-0.240652									
9	7	9	32 동해변전--	대구	대구	2	0.0820218	-4.562E-6	-0.240652									
10	8	17	42 포철소내--	대구	대구	1	8.9996424	0.0861515	-48.27401									
11	9	17	8560 포철소내--	대구	대구	1	8.9996424	-0.086152	48.274006									
12	10	18	96 포철소내--	대구	대구	2	7.7598095	0.0634079	-41.62357	0.0633572	-41.58735	-5.07E-5	0.0362282	0.0799604	0.0870376	9.4521E-6	0.0067539	



Branch P & Q Gap

Put RTDS multimass gen data

Deliverable – In house Tool #3

Research Projects


SSTI analysis tool


$$\therefore J\ddot{\theta} + K\theta = T \quad \text{State equation}$$



Electrical damping analysis



Mechanical damping analysis



HVDC ↔ near CC SSTI analysis results



HVDC ↔ near CC SSTI analysis results






In house tool

[2050 Inertia / Reserve capacity (prediction)]

Renewable Transmission Hosting Capacity

On-going
Research Projects



- Transmission Hosting Capacity – Advance stability analysis method for IBR base grid
- Analysis effect on improvement of Hosting Capacity for the draft reinforcement plans

On-going Research Projects




No Common Operating Point



- Changing DC Power capacity/direction due to some contingencies, according to generators operating conditions and load level
- No common DC operating area → Operation strategy is very complicated
- Need to change the flow level using the HVDC online control system

Generation Constraint Assessment

On-going
Research Projects



- Coal generation is reduced by the constraint shown in the figure above, and instead, LNG power generation is increased
- The cost difference in the figure above is \$1.3M due to the difference in fuel cost
- Delay of transmission line construction became a global trend due to various issues, it is becoming very important to accurately calculate power generation constraints

As-Is

- Korea ISO has applied generation constraints to satisfy reliability standards
 - In particular, constraints amount on the east and west coasts are a lot due to a transient stability
- Peak and off-peak prediction data for a specific period are simulated in advance to derive power system stability limits, and generation constraints are applied based on this
- Excessive generation constraints are applied



To-Be

- Improve the ability to respond power system disturbance by on-line dynamic security assessing
- Find the conditions daily that can maintain power system stability with minimum constraint
- Lower SMP/reducing constraints cost and increase power system stability

CONTENTS

V Discussion



Thank you for your attention!!!